

CERTIFICATE OF COMPLIANCE

Certificate Number 20140710-MH17769
Report Reference MH17769-20120713
Issue Date 2014-JULY-10

Issued to: Alltank Solutions Sdn Bhd
Lot 4009 Jalan Klinik
Kampung Bukit Naga
Batu 6½, Jalan Bukit Kemuning
42450 Klang MALAYSIA

**This is to certify that
representative samples of**

UNDERGROUND TANKS


Series DW-3 fiberglass reinforced plastic secondary containment tanks for petroleum products, for petroleum products and gasohols, or for petroleum products, alcohols and alcohol-gasoline mixtures.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Glass-Fiber-Reinforced Plastic Underground Storage Tanks for Petroleum Products, Alcohols, and Alcohol-Gasoline Mixtures, UL 1316

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

